



POWER & FUEL REQUIREMENTS

NAT. GAS, 162 CU.FT.HR.  
 Propane, 72 CU.FT. or 2 Gal. Per HR.  
 Amp Draw is For Standard 3 HP motor  
     200/3/60 16.5 AMPS  
     230/3/60 14.4 AMPS  
     460/3/60 7.2 AMPS  
 Service outlet 110/1/60 20 AMPS

- |                                |   |
|--------------------------------|---|
| ① 10 GA. GALVANIZED STEEL BASE | ⑥ LIFT OFF LOUVERED DOOR  |
| ② 18 GA GALVANIZED STEEL SKIN  | ⑦ AIR VOLUME CONTROL DAMPERS                                    |
| ③ POWDER COAT FINISH           | ⑧ NEMA 4-12 CONTROL BOX   |
| ④ LIFTING EYES                 | ⑨ RAIN PROOF INTAKE LOUVERS WITH<br>INTREGAL BACK DRAFT DAMPERS |
| ⑤ FABRIC CLAMP CHANNEL         | *⑩ VIBRATION ISOLATORS PROVIDE<br>(1-1/2" high)                 |